

# Report of Discharge (CSO\SSO\RTB)

version 1.9

(Submission #: HNS-F3TV-GXRE9, version 1)

## Details

---

**Form Alias** Report of Discharge (CSO\SSO\RTB)

**Submission #** HNS-F3TV-GXRE9

**Status** Revised

## Form Input

---

### Report Details

**Is this the initial or final discharge report?**

Initial

**Site/Facility Name:**

Lake Mitchell Sewer Authority (former Wexford Co DPW) CM

**Permit Number (if applicable):**

NONE PROVIDED

**Sewer System Owner**

**Contact**

**Prefix**

Mr.

**First Name**

Robert

**Last Name**

Hilty

**Title**

Lake Mitchell Sewer Authority Chair Person

**Organization Name**

Lake Mitchell Sewer Authority

**Phone Type**

**Number**

**Extension**

Business

2317750155

**Email**

operationsoffice@lakemitchellsewer.com

**Fax**

NONE PROVIDED

**Address**

3161 South Lake Mitchell Drive

Cadillac, MI 49601

US

**Facility Address**

3161 South Lake Mitchell Drive

Cadillac, MI 49601

**Sewer System Owner Location**

44.2297714,-85.50879509999999

NONE PROVIDED

## **Discharge Details (1 of 1)**

### **SSO Discharge from Grinder Pump Station 4A SSO**

**Discharge Type:**

SSO Discharge

**SSO Discharge**

The reported discharge is from a private or municipal separate sewer collection system (not a wastewater treatment plant) during wet or dry weather, or a dry weather discharge from a municipal combined sewer collection system.

**Is the outfall or discharge area located at a private residential address?**

NO

**Outfall Name**

Grinder Pump Station 4A SSO

**Outfall Description**

GPS 4A SSO due wipes/grease binding GPS pumps

**Outfall Location**

44.268713,-85.49286560000002

NONE PROVIDED

**Has the discharge ended?**

YES

Volume Discharged	Unit	Was the volume estimated?
25	Gallons	Yes

**Quality of Discharge**

Diluted Raw Sewage

**Please describe the discharge, including the reason for Discharge**

The Sewer Technician was dispatched on September 1, 2019 at 10:00 a.m. and arrived on site at 10:20 a.m. Upon arrival the Tech observed the grinder pump station discharging from the wetwell and on to the surrounding ground. There was no standing water. The Tech noted that pump 1 had a tripped breaker and a 5 amp fuse was blown. The Tech also noted the pump was clogged due to a disposable wipe and grease caught in the pump. Pump 2 was inoperable and will most likely need to be replaced. It was also noted that the station had an excessive amount of grease in the wetwell and on the floats. The Tech cleaned off the floats so they were operable. The residents connected to the station have been given notices before regarding excessive grease and wipes entering the station.

**Was the land or surface water impacted by the discharge?**

Land impacted only

**Name/description of the land impacted:**

Grinder Pump Station 4A and small area of ground surrounding the station

**Discharge Event Start**

Date	Time
9/1/2019	10:00 am

**Discharge Event End**

Date	Time
9/1/2019	10:20 am

**Initial Notification**

Organization	Date	Time
Local Health Department	9/2/2019	12:25 am

Organization	Date	Time
Daily Local Newspaper	9/2/2019	12:25 am

**Notification that discharge has concluded.**

Organization	Date	Time
Local Health Department	9/2/2019	12:25 am
Daily Local Newspaper	9/2/2019	12:25 am

**Precipitation Type(s) (Select none if there was no precipitation)**

None

## **Additional Details**

**Report Submitter**

**Contact**

**Prefix**

NONE PROVIDED

**First Name**

Sheila

**Last Name**

Hill

**Title**

Project Manager

**Organization Name**

Operations Services

**Phone Type**

Mobile

**Number**

2319203034

**Extension**

**Email**

shill@operationsservices.com

**Fax**

NONE PROVIDED

**Address**

3161 South Lake Mitchell Drive

Cadillac, MI 49601

US

**Do you have any additional comments or uploads you would like to provide?**

YES

**Additional Information**

The area that was impacted was raked, broadcast with lime, and taped off as a precautionary measure to keep the public from entering the area. Due to the quick response of the on-call Technician, the SSO was estimated to be very minimal.

**Upload additional information, as needed.**

Sept 1 2019 SSO GPS 4A.jpg - 09/02/2019 01:22 AM

**Comment**

NONE PROVIDED

## **Status History**

	User	Processing Status
9/1/2019 4:55:28 PM	Sheila Hill	Draft
9/2/2019 1:22:47 AM	Sheila Hill	Submitted
9/6/2019 11:05:14 AM	Sheila Hill	Revised

## Revisions

---

Revision	Revision Date	Revision By
Revision 1	9/1/2019 4:55 PM	Sheila Hill
Revision 2	9/6/2019 11:05 AM	Sheila Hill